

CHECK IN SHEET

MODEL #	NRJW 460T6 Rat		SERIAL#	111004337		ID #	
	HOURS:						
ENCLOSURE							
	GOOD	DAMAGED					
LEFT SIDE	X						
RIGHT SIDE	X						
FRONT	X						
REAR	X						
COMMENTS:							

ENGINE:								
MODEL#	G135HF485			SERIAL#	RG6135L04567			
	LEVEL	CONDITION			VOLT	WATT		
OIL	Good				BLOCK HEATER			
COOLANT	Good				RADIATOR			
HOSES	Good				SIZE	VOLTAGE		
BELTS	Good				BATERIES			
					FILTERS			
GENERATOR:	320KW				# 55777 oil #			
	SIZE	POLES			# RE533910x2 #			
BREAKER	1600	3						
	INSPECTED							
WINDINGS	X				INSPECTED			
					CONTROLLER			
	SIZE	LEVEL	CONDITION					
FUEL TANK								

GENERATOR LOAD BANK TEST REPORT

CUSTOMER: Critical Power DATE: 9-19-19

TEST APPROVED BY: Jake Roop TECHNICIAN: _____

MAKE: Ni Power
 MODEL: NRJW460T6 Rndol
 S/N: 111004137
 FUEL: Diesel
 JOBSITE ALTITUDE: _____

KW RATING: 320
 VOLTAGE: 480 PHASE: 3Φ or 208 3Φ
 GOVERNOR: ELECTRONIC
 HOUR METER: 5534 HRS
 TEMPERATURE: _____

TIME OF DAY	VOLTS	AMP	CAL KW	FREQ	OIL PRESS	WATER TEMP	FUEL PRESS	OTHER	
8:45	480	0	0	60	60	120		28.1	0
8:50	480	103	85	60	55	168	99	28.1	25%
8:55	480	192	362	60	54	180	90	28.1	50%
9:00	480	288	240	60	50	171	81	28.1	75%
9:05	480	382	317	60	48	172	81	28.1	100%
9:10	480	382	317	60	48	173	81	28.1	
9:15	480	382	317	60	48	176	82	28.1	
9:20	480	382	317	60	46	177	82	28.1	
9:25	480	382	317	60	46	177	81	28.1	
9:30	480	382	317	60	45	177	81	28.1	
9:35	480	382	317	60	45	177	81	28.1	
9:40	480	382	317	60	44	177	81	28.1	
9:45	480	382	0	60	49	172	100	28.1	0

NOTES/COMMENTS: _____

SIGNATURE: _____