

SPECIFICATIONS, INSPECTION & RUN TEST

MODEL

Whisper Watt DCA800SSK

Make - Model - Application (1500KW 3408 Generator Set)

DATE _____

UNIT SPECIFICATIONS

GENERATOR SET/POWER MODULE									
GENERATOR			ENGINE			POWER UNIT			TRANSMISSION
MAKE Denyo			MAKE Komatsu			MAKE			MAKE
MODEL DF-8800			MODEL SA12V140E-1			MODEL			MODEL
SERIAL NO. 613140			SERIAL NO. IKLXL30.5GC1			SERIAL NO.			ASSY
KW 700	KVA	PHASE 1 <input checked="" type="radio"/> 3	CPL/ARR			HP	RPM	SERIAL NO.	
VOLTAGE 480	WIRE	BREAKER <input checked="" type="radio"/> N	HP 1124	RPM 1800	KW 800	PANEL Y N	MFG DATE	APPL	
PANEL <input checked="" type="radio"/> N	FUEL TANK <input checked="" type="radio"/> N	ENCLOSURE <input checked="" type="radio"/> N	BLOCK HTR Y N	MUFFLER <input checked="" type="radio"/> N	MFG DATE	SKID Y N	MUFFLER Y N	RADIATOR Y N	ADDITIONAL INFO
HOURS 1275			HOURS 1275			HOURS			
PANEL TYPE			GOV TYPE			PTO (TYPE & SIZE)			
FUEL TANK CAPACITY			WEIGHT			WEIGHT			
			RODS & MAINS						

RUN TEST RESULTS

TIME OF DAY	LOAD		VOLTS			AMPS			POWER	Hz	WATER	OIL	FUEL PRESSURE
	%	KW	1	2	3	A	B	C	FACTOR	CPS	DEG F	PSI	
12:25-12:35		100	481	482	480	150	150	150		60.5	81-103		
12:35-12:45		250	480	481	480	336	335	334		60.5	103-117		
12:45-12:55		400	480	481	480	512	512	512		60.5	126-141		
12:55-1:10		500	479	481	479	634	634	632		60.5	141-160		
1:10-2:00		700	479	480	478	871	872	871		60	160-187		

CONDITION OF UNIT

DATE TESTED

TESTED BY

PO #	INV ITEM	COST	
BUYER	BIN LOC	RETAIL	

WHERE DID UNIT COME FROM? ie... Truck pull, out of hospital application, oil field, mine, shady character, etc