



10255 Philadelphia Court
 Rancho Cucamonga, Ca. 91730
 (909) 949-1600
 Fax (909) 949-1999

Official Load Test Report

Customer Power Gen			Cust. #		
Address 4698 Brookhollow Cir		Suite #		P.O. # 4434	
City Riverside		State Ca		Zip 92509	
Site Address			Invoice#		
			Phone		
			Fax		
Site Contact			Title LOAD TEST		
			Cell		

ENGINE		GENERATOR				ATS				
MFG.	John deere	MFG.	Atlas capco			MFG.				
MODEL	60900HFG95	MODEL				MODEL				
SERIAL	RG6090R007730	SERIAL				SERIAL				
ARR.		KW	330	VOLTS	277 - 480	PF-8	VOLTS	120 - 240	PHASE	Single
HOURS	4,550.2	KVA		PHASE	Three	HZ-60	AMPS		POLES	

Time	11:30	11:45	11:46	12:00	12:01	12:15	12:30						
Load%	30	30	50	50	75	75	90						

VOLTS													
L 1-2	478.0	478.0	478.0	478.0	478.0	478.0	477.0						
L 2-3	478.0	478.0	478.0	478.0	478.0	478.0	478.0						
L 3-1	478.0	478.0	478.0	478.0	478.0	478.0	478.0						

AMPS													
L 1	120.2	120.2	199.6	199.5	301.5	301.4	365.3						
L 2	120.4	120.3	199.5	199.5	301.5	301.5	365.5						
L 3	120.4	120.4	199.7	199.7	301.8	301.7	365.7						

LOAD													
KW	100.0	100.0	165.0	165.0	249.0	249.0	300.0						
HZ	60.0	60.0	60.0	59.9	59.9	59.9	59.8						
P.F.	1.0	1.0	1.0	1.0	1.0	1.0	1.0						

Stator °F _____


ENGINE													
Oil psi	58	56	53	52	50	49	47						
Water °F	168	178	183	183	189	193	196						
Fuel psi													
R.P.M.													

GENERATOR EXCITER													
Amps													
Volts													

Comments / Test Results

1hr load test
 15 minutes 30%
 15 minutes 50%
 15 minutes 75%
 15 minutes 90%
 4549.1 - 4550.2

Customer _____ Date 12/3/19

Technician  W/O # L _____