



14519 East Freeway
Houston, TX 77015
936-443-4378

LOAD TEST REPORT

Account Name:
Power Generation Enterprises CAT

Equipment Location: (Physical Address)
In Shop Houston, TX

Engine	Generator
CAT	CAT
3512	

Work Order Number:
[]

PASS / FAIL
PASS

Engine Fluids:

Engine Fluids:	
Oil Level	FULL
Coolant Level	FULL
Beg. Fuel Level	N/A
End Fuel Level	N/A

Service Technician	Test Date
O. BOCANEGRA/ P.BOLIN	Wednesday, January 29, 2020
Customer Witness	
[]	

Test Equipment

Make:	Autron / Simplex
Model:	1200KW / 550KW
Serial Number:	[]

Line	Time	Hour Meter	Volt Meter	Freciancy (Hz)	Power (KW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Pressure (PSI)	Water Temp (F)	Ambient Temp (F)
1	10:00	17,380.0	480	60	0	0	0	0	86	78	48
2	10:01	17,380.0	480	60	360	433	434	433	86	78	48
3	10:16	17,380.3	480	60	360	433	433	433	68	178	48
4	10:31	17,380.5	480	60	360	434	433	433	66	178	48
5	10:31	17,380.5	480	60	700	842	843	843	66	178	48
6	10:46	17,380.8	480	60	700	843	843	843	63	180	48
7	11:01	17,381.0	480	60	700	843	843	843	63	181	48
8	11:01	17,381.0	480	60	1050	1264	1264	1265	63	181	48
9	11:16	17,381.3	480	60	1050	1264	1264	1264	60	184	48
10	11:16	17,381.3	480	60	1390	1673	1673	1674	60	184	48
11	11:31	17,381.5	480	60	1390	1674	1674	1673	60	185	48
12	11:46	17,381.8	480	60	1390	1674	1674	1674	60	185	48
13	12:01	17,382.0	480	60	1390	1674	1673	1674	60	185	48