



Customer: Central States Diesel Generators STK#2701  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 9587  
 Test Date 7-31-20

Engine Make/ Model: Mitsubishi S12A2-Y2PTAW-2  
 Engine Spec/ Serial: 26448  
 Unit Make/ Model: Kohler 750REOZMB  
 Unit Spec/ Serial: 2248554 Spec. GM31728-GA6

Voltage: 277/480  
 Amperage: 914  
 Kilowatts: 760  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	381.8	382	382.3	382.5	382.8	382.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	481	481	480	480
PH3	480	480	480	480	481	480
Amperage PH1	0	914	914	915	914	0
PH2	0	915	915	914	915	0
PH3	0	914	914	914	914	0
Kilowatts	0	760	760	760	760	0
Oil Pressure	80	75	75	75	75	77
Oil Temperature						
Coolant Temperature	170°F	172°F	172°F	172°F	172°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	26.6	26.6	26.6	26.6	26.6	26.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	77°F	77°F	77°F	77°F	77°F	77°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_