



LOADBANK

WO#

DESCRIPTION OF EQUIPMENT			
MAKE	MODEL	SPEC NO.	SERIAL NO.
CAT	SR4		6PA01964
CAT	3512		

BLOCK LOAD		
VOLTS	HERTZ	%
480	60	75
If Applicable		
FILL THESE IN FOR KW		
Power Factor		1.00
Phase (1 or 3)		3

TIME	HRS	HZ	VOLTS	AMPS	BATT	OIL PRESS	WATER	AMBIENT	KW
Warm-up	5095.0	60	480	342	29.2	84	119	78	284.3
0:00	5095.2	60	480	342	29.2	78	147	78	284.3
0:15	5095.4	60	480	342	29.2	65	178	78	284.3
0:30	5095.6	60	480	683	29.2	64	177	78	567.8
0:45	5095.8	60	480	683	29.2	64	178	80	567.8
1:00	5096.0	60	480	683	29.2	64	178	80	567.8
1:15	5096.2	60	480	1025	29.2	64	178	80	852.2
1:30	5096.5	60	480	1025	29.2	64	178	80	852.2
1:45	5096.8	60	480	1025	29.2	64	178	80	852.2
2:00	5097.0	60	480	1025	29.2	64	178	80	852.2
2:15									
2:30									
2:45									
3:00									
3:15									
3:30									
3:45									
4:00									
4:15									
4:30									
4:45									
5:00									
5:15									
5:30									
5:45									
6:00									
6:15									
6:30									
6:45									
7:00									
7:15									

I hereby acknowledge receipt of the above described equipment complete and in satisfactory condition the date and time last above written. I also certify that to the best of my knowledge the repair work done on said equipment has been performed as stated below and is to my complete satisfaction. I understand that no claim for shortage, error or adjustment will be recognized unless made within ten days after the date last above written and on presentation of this copy.

SIGNED: _____

DATE: _____