



QUINN POWER SYSTEMS

RIVERSIDE CA 92502 951-663-6960

LOAD BANK TEST REPORT

DATE: 12/8/2020

ENGINE: JOHN DEERE

MODEL: PE6068HF285

SERIAL NO.: PE6068L071228

CUSTOMER: POWER GENERATION ENTERPRISES

ADDRESS: 4968 BROOKHOLLOW CIRCLE RIVERSIDE CA

JOB NAME: MAGNUM GEN 3

TEST: 30 MIN LOAD BANK

METHOD: RESISTIVE

TESTED BY:

2234

GENERATOR:

MEGR: MAGNUM

MODEL: MMG150

SERIAL NO.:

UNIT RATING: 106KW 3PH 480V

QPS W/O NO.: NR07961

START HOURS: 7048:20:00

END HOURS: 7048:50:00

LOAD %	TIME	UNIT VM VOLTAGE			UNIT AM CURRENT			PFM PF	KWH KW	FM FRQ	AVG AMB	UNIT METERS TEMPERATURE		UNIT METERS PRESSURE	
		1-2	2-3	3-1	1	2	3					WTR F	OIL PSI	FUEL PSI	
80.00%	12:00:00 PM	480	480	480	123	123	123	1		60	75	111		72	
80.00%	12:05:00 PM	479	479	479	122	123	123	1		60	75	185		57	
80.00%	12:10:00 PM	481	480	480	123	123	123	1		60	75	185		48	
80.00%	12:15:00 PM	481	480	480	123	122	123	1		60	75	185		48	
80.00%	12:20:00 PM	481	480	480	123	123	123	1		60	75	185		48	
80.00%	12:25:00 PM	481	480	480	123	123	123	1		60	75	185		48	
80.00%	12:30:00 PM	481	480	480	123	123	123	1		60	75	185		48	

NOTES: