



14519 East Freeway
Houston Texas, 77024
936-443-4378

LOAD TEST REPORT

Account Name:
Power Generation Enterprises

Equipment Location: (Physical Address)
Shop

Work Order Number:

Engine	Generator
CAT	CAT
3456	SR4
3PG01060	CER00797

PASS / FAIL
PASS

Engine Fluids:

Engine Fluids:	
Oil Level	Full
Coolant Level	Full
Beg. Fuel Level	75%
End Fuel Level	50%

<u>Service Technician</u>	<u>Test Date</u>
Oscar B	Monday, January 18, 2021
<u>Customer Witness</u>	

Test Equipment

Make:	Simplex
Model:	660KW
Serial Number:	_____

Line	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (KW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Pressure (PSI)	Water Temp (F)	Ambient Temp (F)
1	9:25	1963.00	479	60	0	0	0	0	80	136	55
2	9:26	1963.00	479	60	155	191	190	190	72	171	55
3	9:41	1963.00	479	60	155	191	190	190	65	187	55
4	9:56	1963.00	479	60	155	191	190	190	65	187	55
5	9:57	1963.00	479	60	310	374	374	374	63	189	55
6	10:12	1963.00	479	60	310	374	373	373	63	189	55
7	10:28	1964.00	479	60	310	374	373	373	63	189	55
8	10:29	1964.00	479	60	500	597	596	596	60	194	55
9	10:44	1964.00	479	60	500	596	596	596	58	203	55
10	10:59	1964.00	479	60	500	596	596	596	57	201	55
11	11:14	1964.00	479	60	500	596	596	596	58	203	55
12	11:29	1965.00	479	60	500	596	596	596	58	201	55
13	11:39	1965.00	479	60	0	0	0	0	70	180	55