

Load Test Data Report



| | | | |
|------------------|-----------------|----------------|---------------|
| Customer | VICTOR | Site | |
| Engine Make | JOHN DEERE 6.8L | Generator Make | MQ POWER |
| Engine M/N | 6068HF485T | Generator M/N | DCA-180SSJU |
| Engine S/N | 6JDXL06.8101 | Generator S/N | 8900014 |
| KW | 150 | VAC | 480 |
| Facility Manager | | Date | 4/14/2021 |
| Technician | SCOTT GOODBAR | Hours | 283.5 / 284.5 |

| Time | Vac AB | Vac BC | Vac CA | Iac A | Iac B | Iac C | Power Factor | KW | RPM | Oil Pressure | Coolant Temp | Ambient Temp | HZ | Temp Oil | Frame Temp |
|------|--------|--------|--------|-------|-------|-------|--------------|-----|------|--------------|--------------|--------------|----|----------|------------|
| 0950 | 480 | 480 | 480 | 90 | 90 | 90 | 1.0 | 75 | 1800 | 52 | 170 | 65 | 60 | 125 | 60 |
| 1000 | 480 | 480 | 480 | 172 | 172 | 172 | 1.0 | 144 | 1800 | 49 | 190 | 65 | 60 | 156 | 65 |
| 1010 | 480 | 480 | 480 | 178 | 178 | 178 | 1.0 | 148 | 1800 | 45 | 202 | 65 | 60 | 176 | 65 |
| 1020 | 480 | 480 | 480 | 178 | 178 | 178 | 1.0 | 149 | 1800 | 40 | 205 | 65 | 60 | 180 | 72 |
| 1030 | 480 | 480 | 480 | 178 | 178 | 178 | 1.0 | 149 | 1800 | 38 | 205 | 46 | 60 | 184 | 80 |
| 1040 | 480 | 480 | 480 | 90 | 90 | 90 | 1.0 | 75 | 1800 | 38 | 195 | 46 | 60 | 184 | 80 |
| 1050 | 480 | 480 | 480 | 90 | 90 | 90 | 1.0 | 75 | 1800 | 40 | 190 | 46 | 60 | 178 | 80 |
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |

NOTES: PERFORMED ANNUAL LOAD TEST AND ALL OPERATION IS NORMAL AT THIS TIME.