



14519 East Freeway  
Houston Texas, 77024  
936-443-4378

# LOAD TEST REPORT

**Account Name:**  
Power Generation Enterprises

**Equipment Location: (Physical Address)**  
Shop

**Work Order Number:**  
\_\_\_\_\_

Engine	Generator
	MQ
	DCA5005500
	9100277

<b>PASS / FAIL</b>
<i>Pass</i>

**Engine Fluids:**

Engine Fluids:	
Oil Level	Full
Coolant Level	Full
Beg. Fuel Level	Full
End Fuel Level	

<b><u>Service Technician</u></b>	<b><u>Test Date</u></b>
Oscar B	Monday, April 5, 2021
<b><u>Customer Witness</u></b>	

**Test Equipment**

Make:	Simplex
Model:	660KW
Serial Number:	

Line	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (KW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Pressure (PSI)	Water Temp (F)	Ambient Temp (F)
1	12:50	159.90	480.00	60	0	0	0	0	55	165	78
2	12:51	159.90	480.00	60	75	93	93	93	50	180	78
3	1:06	160.10	480.00	60	75	93	93	93	50	180	78
4	1:21	160.30	480.00	60	75	93	93	93	50	180	78
5	1:22	160.30	480.00	60	150	197	153	200	45	195	78
6	1:37	160.70	480.00	60	150	197	153	200	45	195	78
7	1:52	160.90	480.00	60	150	197	153	200	45	195	78
8	1:53	160.90	480.00	60	150	288	284	288	46	205	78
9	2:08	161.30	480.00	60	240	288	284	288	40	205	78
10	2:23	161.50	480.00	60	240	288	284	288	40	205	78
11	2:38	161.70	480.00	60	240	288	284	288	40	205	78
12	2:53	161.90	480.00	60	240	288	284	288	40	205	78
13	3:03	161.90	480.00	60	0	0	0	0	50	180	78