



14519 East Freeway
Houston Texas, 77024
936-443-4378

LOAD TEST REPORT

Account Name:

Equipment Location: (Physical Address)

Work Order Number:

Engine	Generator
<input type="text"/>	<input type="text"/>
<input type="text"/>	<input type="text"/>

PASS / FAIL
Pass

Engine Fluids:

Engine Fluids:	<input type="text"/>
Oil Level	<input type="text"/>
Coolant Level	<input type="text"/>
Beg. Fuel Level	<input type="text"/>
End Fuel Level	<input type="text"/>

<u>Service Technician</u>	<u>Test Date</u>
<input type="text"/>	<input type="text"/>
<u>Customer Witness</u>	
<input type="text"/>	

Test Equipment

Make:	<input type="text"/>
Model:	<input type="text"/>
Serial Number:	<input type="text"/>

Line	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (KW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Pressure (PSI)	Water Temp (F)	Ambient Temp (F)
1	10:44	3820.54	480.00	60	0	0	0	0	102	105	88
2	10:45	3820.55	480.00	60	432	520	520	520	82	163	88
3	11:00	3821.10	480.00	60	432	520	520	520	80	165	88
4	11:15	3821.25	480.00	60	432	520	520	520	80	165	89
5	11:15	3821.25	480.00	60	720	866	866	866	80	165	89
6	11:30	3821.40	480.00	60	720	866	866	866	79	166	89
7	11:45	3821.55	480.00	60	720	866	866	866	79	167	89
8	11:45	3821.55	480.00	60	1152	1385	1385	1385	79	168	90
9	12:00	3822.10	480.00	60	1152	1385	1385	1385	79	172	90
10	12:15	3822.25	480.00	60	1152	1385	1385	1385	79	174	90
11	12:30	3822.40	480.00	60	1440	1734	1734	1734	79	174	90
12	12:45	3822.55	480.00	60	1440	1734	1734	1734	65	194	94
13	12:50	3823.00	480.00	60	0	0	0	0	83	161	94