

# Generator load Test Data Report



3500 Shepherd St., Whittier, CA 90808

562-463-6000

Project	Power Generation Services			Site	shop
Customer	Same			KW	600
Engine M/N	3412DITA	Generator M/N	SR4	VAC	480/277
Engine S/N	81Z08979	Generator S/N	6FA05600	Date	10/25/2021
Technician	D JACKSON	Job Number	RT02848		

Time	Vac AB	Vac BC	Vac CA	Iac A	Iac B	Iac C	KW	Hz	Oil Press	Coolant Temp	Amb Temp	Load %					
915	482	483	483	179	179	178	149.4	60.0	74	179	61'	25%					
930	482	483	483	362	363	363	303.2	60.0	70	181	61'	50%					
945	482	483	483	539	539	540	450.9	60.0	66	185	61'	75%					
1000	483	483	483	726	727	726	607.6	60.0	63	192	61'	100%					
1015	484	483	483	727	727	726	608.3	60.0	61	192	61'	100%					
1030	484	481	482	727	726	726	606.8	60.0	60	193	61'	100%					
1045	484	481	483	727	727	727	607.8	60.0	58	193	62'	100%					

Customer

Technician *David Jackson*