

Quinn Power Systems General Service Form

PM

● 0 ● 0 ● 7 ● 0

Inspection Number	6828731		
Make	MULTIQUIP INC.	Customer No	759400
Serial Number	WA-542180-1140	Customer Name	Ziegler CAT
Model	Standby	Customer Phone	7608614771
Equipment Family	ENGINE - GENERATOR SET	Customer Email	linda.vogel@zieglercat.com
Asset ID	PM2, PM3, Battery Replacement Kathy Doolittle	Completed On	9/20/2021 7:47:04 AM
SMU	62.6 Hours	Inspector	Joseph Denning
Location	Get Direction	Work Order	NR09726
Coordinates	0, 0, 0	PDF Generated On	9/20/2021
Technician			

General Info & Comments

● **General info/Comments** NORMAL

Service

● **1.1 Scope of work** CHECKED

Comments: Removed and replaced the batteries. Performed annual load bank test.



● **1.2 Start time: End time:** COMPLETED



● 1.3 Test run generator to make sure no leaks by filters PERFORMED

● 1.4 Generator back in auto COMPLETED



● 1.5 Technician recommendation GOOD

● 1.6 Submit report to customer COMPLETE