



GenSolutions LLC

14519 East Freeway
Houston Texas, 77024
936-443-4378

LOAD TEST REPORT

Account Name:

Power Generation Enterprises

Equipment Location: (Physical Address)

In Shop

Engine

Generator

MO

DCAI80SSV

3774075

Work Order Number:

PASS / FAIL

Pass

Engine Fluids:

Oil Level	Full
Coolant Level	Full
Beg. Fuel Level	N/A
End Fuel Level	N/A

Service Technician

J. MIRANDA

Test Date

Tuesday, October 5, 2021

Customer Witness

Test Equipment

Make:

Model:

Serial Number:

SIMPLEX

600 KW

Line	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (KW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Pressure (PSI)	Water Temp (F)	Ambient Temp (F)
1	10:00	4130	480.00	60	40	48	48	48	75	150	90
2	10:15	4130	480.00	60	40	48	48	48	65	180	90
3	10:30	4130	480.00	60	40	48	48	48	65	180	90
4	10:30	4130	480.00	60	75	90	91	91	65	180	90
5	10:45	4130	480.00	60	75	91	91	90	60	190	90
6	11:00	4130	480.00	60	75	91	91	91	60	190	90
7	11:00	4130	480.00	60	110	132	132	133	60	190	90
8	11:15	4130	480.00	60	110	133	133	133	60	190	90
9	11:30	4130	480.00	60	110	133	133	133	60	190	90
10	11:30	4130	480.00	60	140	169	169	169	60	190	90
11	11:45	4130	480.00	60	140	169	170	169	60	195	90
12	12:00	4130	480.00	60	140	169	169	169	60	195	90
13	12:05	4130	480.00	60	0	0	0	0	0	180	90