



### Loadbank Report

Date: 2/21/22 Job No.: NR10546

Tech ID: 7311 Job Type: Contract Services

Tech Name: 0

3500 Shepherd St., City of Industry, CA 90601 - (562) 463-6051

Store: 37 Phone #: (909)443-8712

### Customer Information

Account : 271504K

Agreement #: 1834AD

Site Name:	Power Generation	Billing Name:		Contact Name:	Victor
Address:		Billing Address:		Office #:	
City:		City:		Mobile #:	
Zip:		Billing Zip:		Email:	

### Equipment Information

### GENERATOR

Engine Make:	CAT		Generator Make:	CAT			Meter Hour Start:	10:40am 10147hrs warm up		Phase:	3
Engine Model:	3508		Generator Model:	SR4			Meter Hour Stop:	10148hrs 1pm cooldown		Amps:	1128
Engine Serial #:	3LS00216		Generator Serial #:	5UA00806			Generator Arrange #:			Hertz:	60
Engine Spec #:			Generator Rated kW:	750			Volt AC:	480		kVA:	938
Load Duration	1 Hour		Power Factor	1.0			Volt DC:			Barometric Pressure	
Time (use 24 hrs Time)	Load %	KW	Vac AB	Vac BC	Vac CA	Iac A	Iac B	Iac C	Hertz	Oil Press	Coolant Temp
11:50	27%	200.8	480	480	485	240	242	240	60.0	72	109
12:05	53%	401.0	480	480	485	480	482	480	60.0	70	141
12:20	71%	532.3	481	481	480	639	640	639	60.0	67	168
12:35	71%	532.3	481	481	480	639	640	639	60.0	67	168
12:50	103%	775.6	481	481	480	930	934	931	60.0	65	188

**COMMENTS:**

Checked fluids, warmed up unit connected load cables and load bank for an hour, steps were added every 15 minutes no leaks or issues were found units. No recommendations at this time.

Customer Signature:

Technician Signature:

Print Name:

Victor

Customer Phone #:

0