

# Load Test Data Report



3500 Shepherd St., City of Industry, CA 90601

562-463-6073

Project	2 Hour Load Bank Report		
Customer	QPS Rental	Site	COI Rental Department
Engine M/N	C15	Generator M/N	LC6 - G6822324
Engine S/N	JJF01267	Generator S/N	X5M00436
KVA	569 - KW 455	VAC	480
Job Number	WX73698 - 01	DATE	5/10/2022
Technician	1163		

Time	Vac AB	Vac BC	Vac CA	Iac A	Iac B	Iac C	Power Factor	Excitor Vac	Excitor Iac	KW	RPM	Oil Pressure	Coolat Temp	Engine HRS	Battery Volt	Boost Pressure	KW%
0900	481	481	481	-	-	-	1.00	8V	1A	42	1800	82	174	19064	28.2V	4	8
0915	481	481	481	137	137	137	1.00	10V	1A	135	1800	78	176	19064	28.2V	10	30
0930	481	481	481	297	297	297	1.00	12V	1A	247	1800	77	181	19065	28.2V	25	50
0945	481	481	481	452	452	452	1.00	17V	2A	377	1800	74	190	19065	28.2V	34	75
1000	482	481	481	586	584	586	1.00	22V	2A	488	1800	73	203	19066	28.2V	39	98
1015	481	481	481	518	518	520	1.00	20V	2A	432	1800	71	208	19066	28.2V	38	85
1030	481	481	481	518	518	520	1.00	20V	2A	432	1800	71	208	19066	28.2V	38	85
1045	481	481	481	519	518	519	1.00	20V	2A	432.00	1800	70	212	19066	28.2V	39	85
1100	481	481	481	519	518	519	1.00	20V	2A	432.00	1800	70	212	19066	28.2V	39	85