

Customer PowerGen Services			Cust. #		
Address _____		Suite #		P.O. #	
City _____		State _____		Zip _____	
Site Address 4698 Brookhollow Circle			Invoice#		
Riverside CA,			Phone		
Site Contact _____			Title _____		
Cell					

ENGINE		GENERATOR				ATS				
MFG.	Cummins	MFG.	MQ Power			MFG.				
MODEL	QSB7 -G7	MODEL	DF1651C			MODEL				
SERIAL	73404440	SERIAL				SERIAL				
ARR.		KW	120	VOLTS	277 - 4 <input type="checkbox"/>	PF-8	VOLTS	120 - 240 <input checked="" type="checkbox"/>	PHASE	Three
HOURS	13129.6- 13130.6	KVA		PHASE	Three <input type="checkbox"/>	HZ-60	AMPS		POLES	

Time	11:45	12:00	12:01	12:15	12:16	12:30	12:31	12:45					
Load%	25	25	50	50	75	75	100	100					

VOLTS													
L 1-2	480	480	480	480	480	480	480	480					
L 2-3	482	482	482	482	482	482	482	482					
L 3-1	482	482	482	482	482	482	482	482					

AMPS													
L 1	38	38	75	75	105	105	147	147					
L 2	38	38	76	76	106	106	148	148					
L 3	38	38	75	75	106	105	147	147					

LOAD													
KW	30	30	60	60	90	90	120	120					
HZ	60	60	60	60	60	60	60	60					
P.F.	1	1	1	1	1	1	1	1					

Stator °F _____

ENGINE													
Oil psi	60	60	60	61	60	60	59	59					
Water °F	175	175	180	188	188	188	190	189					
Fuel psi													
R.P.M.	1801	1801	1800	1800	1800	1800	1799	1799					

GENERATOR EXCITER													
Amps													
Volts													

Comments / Test Results _____