

ENGINE		GENERATOR				ATS			
MFG.	Cummins	MFG.	Onan			MFG.			
MODEL	NTA-855-G5	MODEL	DFCE-3387244			MODEL			
SERIAL	30363691	SERIAL	A000039692			SERIAL			
ARR.		KW	400	VOLTS	277 - 4	PF-8	VOLTS	PHASE	Three
HOURS	396.4- 397.3	KVA	500	PHASE	Three	HZ-60	AMPS	POLES	

Time	12:30	12:45	1:00	1:15	1:30								
Load%	50	50	75	75	75								
VOLTS													
L 1-2	477	478	478	478	478								
L 2-3	478	478	478	478	478								
L 3-1	478	478	478	478	478								
AMPS													
L 1	246	244	366	367	366								
L 2	242	240	365	365	365								
L 3	243	241	365	365	365								
LOAD													
KW	200	200	300	300	300								
HZ	60	59.9	60	60	60								
PF	1	1	1	1	1								
Stator "F"													
ENGINE													
Oil psi	54	52	49	49	49								
Water "F"	179	181	182	183	183								
Fuel psi													
R.P.M.	1799	1798	1805	1802	1800								
GENERATOR EXCITER													
Amps													
Volts													

Comments / Test Results

Performed a 1 hour load test. unit ran with loads of 50% for 30 min, and 75% for 30 min. Unit ran with no issues to report.