

Official Load Test Report

Customer <small>vic</small>			Cust. #		
Address		Suite #		P.O. #	
City		State		Zip	
Site Address			Invoice#		
			Phone		
			Fax		
Site Contact		Title		Cell	

ENGINE		GENERATOR				ATS	
MFG.	Volvo	MFG.	General Power		MFG.		
MODEL	LVPXL16 1ACC	MODEL	GP- V515E		MODEL		
SERIAL	2016135170	SERIAL	X26985E		SERIAL		
ARR.		KW	521	VOLTS	277 - 4	PF-8	
HOURS	1:36- 2:36	KVA	651	PHASE	Three	AMPS	
						POLES	

Time	2:15	2:30	2:45	3:00	3:15								
Load%	30	50	75	100	100								

VOLTS													
L 1-2	479	480	479	479	480								
L 2-3	481	479	479	480	479								
L 3-1	479	479	480	480	482								

AMPS													
L 1	189	320	470	620	620								
L 2	189	320	470	620	620								
L 3	189	320	470	620	620								

LOAD													
KW	156.3	260.5	390.7	520	520								
HZ	60	60	60	60	60								
P.F.	1	1	1	1	1								

Stator °F

--	--	--	--	--	--	--	--	--	--	--	--	--	--

ENGINE													
Oil psi	80	92	83	80	78								
Water °F	177	179	181	179	181								
Fuel psi													
R.P.M.	1800	1800	1800	1800	1800								

GENERATOR EXCITER													
Amps													
Volts													

Comments / Test Results
 performed 1 hr load test. Generator ran with loads of 30% for 15 min, 50 for 15 min, 75% for 15 min, and 100% for 15 min. Unit performed wiyh no issues to report.