

Official Load Test Report

Customer <u>Power Gen Services</u>		Suite # _____		Cust. # _____	
Address _____		State <u>Ca</u>		P.O. # _____	
City _____		Zip <u>91711</u>		Invoice# _____	
Site Address <u>4696 Brookholow Circle</u>		_____		Phone _____	
Riverside CA _____		_____		Fax _____	
Site Contact _____		Title _____		Cell <u>(909) 399-5527</u>	

ENGINE		GENERATOR				ATS				
MFG.	Cummins	MFG.	Whisperwall			MFG.				
MODEL	QSL3-03	MODEL	DCA-3005SCU			MODEL				
SERIAL	73214640	SERIAL	9100292			SERIAL				
ARR.		KW	240	VOLTS	277 - 48 ▼	PF-8	VOLTS	120 - 240 ▼	PHASE	Single ▼
HOURS	4,520.3	KVA	300	PHASE	Three ▼	HZ-60	AMPS		POLES	

Time	11:00	11:15	11:30	11:45	12:00	12:15	12:30	12:45	1:00	1:15	1:30	1:45	2:00	2:15	2:30	2:45	3:00
Load%	50	50	75	75	100	100											
VOLTS																	
L-1-2	476.0	476.0	476.0	475.0	474.0	474.0											
L-2-3	477.0	477.0	477.0	477.0	476.0	476.0											
L-3-1	475.0	475.0	474.0	475.0	474.0	474.0											
AMPS																	
L-1	147.0	147.0	219.0	219.0	294.0	294.0											
L-2	147.0	147.0	220.0	220.0	293.0	293.0											
L-3	146.0	146.0	218.0	219.0	293.0	293.0											
LOAD																	
KW	120.0	120.0	180.0	180.0	240.0	240.0											
HZ	61.0	60.0	60.0	60.0	60.0	60.0											
PF	1.0	1.0	1.0	1.0	1.0	1.0											
Stator T																	
ENGINE																	
Oil psi	60	65	65	65	65	65											
Water T	145	185	195	195	195	195											
Fuel psi																	
RPM	1,800	1,800	1,800	1,800	1,800	1,800											
GENERATOR EXCITER																	
Amps																	
Vols																	

Comments / Test Results

15 minutes 50%load
 15 minutes 75%load
 15 minutes 100%load
 4519.6 - 4520.3

Customer _____	Date <u>11/6/02</u>
Technician <u>[Signature]</u>	W/O # <u>L</u>