LOAD TEST REPORT

GenSolutions LLC

14519 East Freeway
Houston Texas, 77024
936-443-4378

Account Name:

Service Address: INSHOP

Work Order Number:

Engine	Generator
	IR
	G570
	404529UISB54

PASS / FAIL
PASS

Engine Fluids:

Engine Fluids:	
Oil Level	FULL
Coolant Level	FULL
Beg. Fuel Level	
End Fuel Level	

Service Technician	Test Date
JOSE	Wednesday, February 15, 2023

Customer Witness

Load Bank

Make:	AVTRON
Model:	1250KW
Serial Number:	

Line	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (KW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Pressure (PSI)	Water Temp (F)	Ambient Temp (F)
1	1:15	278.9	480	60	455	548	549	548			71
2	1:30	279.2	480	60	455	548	549	547			71
3	1:45	279.4	480	60	455	549	549	547			71
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											