LOAD TEST REPORT

GenSolutions LLC
14519 East Freeway
Houston Texas, 77024
936-443-4378

Account Name: Power Generation Ent

Equipment Location: (Physical Address) IN SHOP

Work Order Number:

Engine	Generator
	BROADCROWN
	ACBCJD440S
	EXP38143

PASS / FAIL
PASS

Engine Fluids:

Engine Fluids:	
Oil Level	FULL
Coolant Level	FULL
Beg. Fuel Level	
End Fuel Level	

Service Technician	Test Date
JOSE	Monday, May 15, 2023

Customer Witness

Load Bank

Make:	SIMPLEX
Model:	700KW
Serial Number:	

Line	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (KW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Pressure (PSI)	Water Temp (F)	Ambient Temp (F)
1		199.31	240	60	400	963	964	963	83	134	85
2		199.46	240	60	400	963	964	963	76	188	85
3		200.1	240	60	400	963	964	963	76	188	85
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											