

GEN SET KW
175
GEN SET KVA
216
GEN SET VOLT
240
GEN SET AMPS
616

TECH NAME
JAVIER ZAMORA
TECH #
2838
DATE
5/25/2023

TEST TIME	WARMUP	SAMPLE INTERVAL																COOLDOWN
		MINUTES	15	30	45	60	75	90	105	120	135	150	165	180	195	210	225	
HOURS		0.25	0.5	0.75	1	1.25	1.5	1.75	2	2.25	2.5	2.75	3	3.25	3.5	3.75	4	
ENGINE																		
OIL PRESSURE	77	62	60	59	60													65
COOLANT TEMP.	177	178	179	182	184													175
D.C. VOLTAGE	28	27	27	27	27													28
R. EXHAUST TEMP	469	1060	1065	1047	1055													483
L. EXHAUST TEMP	N/A	N/A	N/A	N/A	N/A													N/A
AMBIENT TEMP	78	79	80	81	83													84
GENERATOR																		
VOLTAGE																		
A-B	247	245	245	245	245													247
B-C	246	244	244	245	245													246
C-A	245	243	243	243	243													245
VOLTAGE AV.	246	244	244	244.3	244.3	0	0	0	0	0	0	0	0	0	0	0	0	246
AMPERAGE																		
A	24	346	345	345	346													24
B	24	348	347	347	348													25
C	25	349	348	349	349													24
AMPERAGE AVG.	0	347.7	346.67	347	347.7	0	0	0	0	0	0	0	0	0	0	0	0	24.33
KWATTS CAL.	10.37	146.9	146.5	146.8	147.1	0	0	0	0	0	0	0	0	0	0	0	0	10.37
KVA	0.00	146.9	146.5	146.8	147.1	0	0	0	0	0	0	0	0	0	0	0	0	10.37
FREQUENCY	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60	60
POWER FACTOR	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
% LOAD	5.924	84	83.72	83.9	84.1	0	0	0	0	0	0	0	0	0	0	0	0	5.92

GEN SET MAKE
CAT
GEN SET MODEL
XQ225
GEN SET SER. #
6PK00608
GEN SET ARR.#

ENGINE MAKE
CAT
ENGINE MODEL
3306
ENGINE SER. #
8JJ00158
ENGINE ARR.#

ENGINE HOURS
START **STOP**
13656 13658
JOB #
LE56833

CUSTOMER NAME
USED SALES

NOTES