LOAD TEST REPORT

GenSolutions LLC

14519 East Freeway
Houston Texas, 77024
936-443-4378

Account Name:

Equipment Location: (Physical Address)
IN SHOP

Work Order Number:

Engine	Generator
	BROADCROWN
	BCV550
	EXP375545

PASS / FAIL

Engine Fluids:

Engine Fluids:	
Oil Level	FULL
Coolant Level	FULL
Beg. Fuel Level	
End Fuel Level	

Service Technician	Test Date
JOSE	Thursday, June 29, 2023

Customer Witness

Load Bank

Make:	SIMPLEX
Model:	660KW
Serial Number:	

Line	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (KW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Pressure (PSI)	Water Temp (F)	Ambient Temp (F)
1	11:15	191.24	480	60	435	524	524	525	79	138	98
2	11:30	191.39	480	60	435	524	524	525	73	191	98
3	11:45	191.59	480	60	435	524	524	524	73	191	98
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											