

10272



PROTECTED SECONDARY CONTAINMENT GENERATOR BASE TANK  
UL 2085

NO. S/C-00951-4

SST LTD.

DATE: 4/7/86

MODEL: 36677

CAPACITY: 3000

THIS TANK REQUIRES EMERGENCY RELIEF VENTING NOT LESS THAN:  
CUBIC FEET PER HOUR. (PRIMARY TANK) AND NOT  
LESS THAN: 462224 CUBIC FEET PER HOUR (SECONDARY/ANNULAR SPACE)  
462662

BALLISTIC AND IMPACT RESISTANT

THIS TANK SHALL BE INVESTIGATED TO DETERMINE ACCEPTABILITY FOR USE  
AFTER FIRE EXPOSURE OR OTHER PHYSICAL DAMAGE, OR MISUSE.  
PRESSURIZE PRIMARY TANK WHEN PRESSURE TESTING ANNULAR SPACE.

THIS TANK IS INTENDED FOR STATIONARY INSTALLATION ONLY.  
FOLLOW INSTALLATION INSTRUCTIONS.

THIS TANK IS INTENDED FOR INSTALLATION IN ACCORDANCE WITH  
NFPA 30, NFPA 37 AND/OR UNIFORM FIRE CODE.



**ACOUSTICAL CONTROL  
SYSTEMS, INC.**

**SHERMAN, TEXAS USA**

WEATHER ENCLOSURE

**ASSEMBLY DESCRIPTION**

10692-10

ACSS 02-300

**JOB NO.**

**CODING**

10692-10

**ASSEMBLY DWG NO.**

PO# 73356

**CUSTOMER P.O.**

UNIT B



05/18/2013