

**ENGINE TEST (CTP)****(CTP)-ENGINE (4RJ)-GENERATOR (KAP)-GENSET****JANUARY 30, 2008**Phone Numbers [Click here](#)

Sales Model: 3412

Built Date: Jan2007

Tested Date: Jan2007

Shipped Date: Mar2007

Tested: B

Test Number: 02

Cell Number: 21

Test Element	Eng Updates	Test Value	Spec Value	Label
Spec Number		OK6123	OK6123	
Arrangement Number		2021316	2021316	
CORR FL PWR		624	621	HP
Speed		1,801	1,800	RPM
CORR FL FUEL RATE		79,815.7	77,531.4	BTU/MIN
CSFC		7,680	7,492	BTU/HP-H
Jacket Water Temp		192	192	F
IN SCAC H2O		126	129	F
Compressor Out Pressure		23.50	23.21	PSIA
Inlet Manifold Pressure		20.60	20.45	PSIA
Excess Oxygen		0.5	0.5	%
Nox Level				PPM
FL Oil Press		69	65	PSI
High Speed		1,800	1,800	RPM
Diff Fuel Pressure High		0.20	0.22	PSI
Low Idle Speed		1,200	1,200	RPM
Low Idle Oil Pressure		66	61	PSI
Fuel Pressure		17	18	PSIA
Timing BTDC				DEG
Advertised Power			621	hp
Advertised Speed			1,800	RPM

Caterpillar Confidential: Green Content  
 Owner: Alan Scott Web Master(s): [PSG Web Based Systems Support](#) Current Date:  
 Wednesday, January 30, 2008 11:16:56 AM ©  
 Caterpillar Inc. 2008 All Rights Reserved.  
[Data Privacy Statement.](#)