

3406B GEN SET ENGINE

Engine Serial Number Prefix - 4PM (Build Date - 20/10/1995, Test Date - 20/10/1995, Ship Date - 07/11/1995)

ENGINE - ENTIRE GROUP PREFIX (4PM)

Qty.	NPR	Note	Part No.	Change Level	Qty Req.	Part Name
PART NUMBERS						
		I	CA0160	01	001	3406 300 EKW 277/480 V 60 HZ
	NPR	IY	111-1304	04	001	ENGINE AR
	NPR	IY	1W-7411	02	001	CONTROL GP-GOVERNOR
	NPR	IY	2W-8198	08	001	SHUTOFF GP-ELECTRICAL
		I	3L-0212	04	001	PKG. G.S. ELECTRICAL SYS. TEST
	NPR	IY	4N-1062	10	001	STARTING MOTOR GP-ELECTRIC
	NPR	IY	4N-3287	07	001	PUMP GP-FUEL PRIMING
	NPR	IY	4P-7610	02	001	SENSOR GP-SPEED
		I	5N-7563		001	NOTE- CONTROL PANEL MTG (RH)
		I	5P-2506	00	001	LITERATURE GP
	NPR	I	5P-2586	03	001	OIL
	NPR	I	6I-3339	00	001	NEUTRAL BUS BAR AS
	NPR	IY	6L-2927	07	001	ELBOW GP-EXHAUST
	NPR	IY	9Y-6103	01	001	AIR CLEANER GP
	NPR	IY	109-3319	01	001	COUPLING GP-GENERATOR

NPR	IY	110-9690	00	001	BASE GP-ENGINE & GENERATOR
NPR	IY	111-1313	04	001	WIRING GP
NPR	IY	111-7200	00	001	LINES GP-ENGINE OIL DRAIN
NPR	IY	111-8256	00	001	MOUNTING GP-CIRCUIT BREAKER
NPR	IY	112-2980	01	001	FASTENER GP-PANEL
NPR	IY	112-9850	00	001	FITTING GP-EXHAUST
NPR	IY	114-0863	00	001	CONTACTOR GP
NPR	IY	116-5516	00	001	GUARD GP-BELT
NPR	I	121-6873	00	001	GENERATOR AR
	I	5N-7600		001	NOTE-CTL & PWR PNL CHT 1231334
NPR	IY	115-9322	00	001	GUARD GP-RADIATOR
	I	CA0054	02	001	RADIATOR AR-OPTIONAL
NPR	IY	4N-3093	08	001	FAN GP-BLOWER
NPR	IY	4N-9778	03	001	LINES GP-WATER
NPR	IY	7N-8837	02	001	DRIVE GP-FAN
NPR	I	115-9545	01	001	RADIATOR GP
NPR	IY	111-7199	00	001	LINES GP-COOLANT DRAIN
	I	CA0142	01	001	COOLING SYSTEM PROTECTION-ANTI
NPR	I	2P-9868	04	001	ANTIFREEZE
	I	CA0136	01	001	GOVERNOR GP-WOODWARD 8290
	I	2T-6254	00	001	335 KW @ 1800 RPM (449 BHP)
NPR	I	111-4421	01	001	ACTUATOR AS-GOVERNOR
NPR	IY	111-7534	01	001	MOUNTING GP-ACTUATOR
NPR	IY	116-2828	03	001	PUMP GP-GOV & FUEL INJ
NPR	I	9Y-4812	02	001	LINES GP-FLEXIBLE FUEL

WITH

NPR	IY	112-5716	02	001	FUMES DISPOSAL GP
	I	CA0036	01	001	HEATER GP-JACKET WATER-3 KW
NPR	I	115-9629	02	001	HEATER GP-JACKET WATER
NPR	IY	115-9607	01	001	MOUNTING GP-JACKET WTR HEATER
	I	CA0057	01	001	CHARGER AR-BATTERY WITH ALARMS
NPR	I	111-6138	02	001	BATTERY CHARGER
NPR	IY	111-6139	01	001	FASTENER GP-BATTERY CHARGER
	I	CA0227	00	001	BATTERY GP
NPR	I	7L-7872	07	001	BATTERY GP
NPR	IY	111-2518	02	001	SUPPORT GP-BATTERY
	I	CA0075	00	001	REMOVAL AR-500 AMP CIRCUIT BRE
	I	CA0092	00	001	BREAKER GP-CIRCUIT-600 AMP
NPR	IY	105-7185	00	001	HARNESS AS-PANEL
NPR	IY	111-9705	00	001	CIRCUIT BREAKER GP
	I	CA0130	00	001	ALARM MODULE-NFPA 99
NPR	IY	112-6366	01	001	SWITCH GP
NPR	IY	114-0864	01	001	CONTACTOR GP-ALARM
	I	0P-1895		001	TFD3JX211SEPBXX2CXXX0 PANE
	I	0P-1839		001	A10 EMCPII PANEL
	I	5N-7595		001	NOTE - MOUNT CIRCUIT BKR RH
	I	0P-9715		001	EXTRA LITERATURE-G.S. M/AUX
	I	0P-1803		001	GEN SET TEST CHG AT 0.8 PF
	I	0P-1530		001	GENERATOR TEST REPORT

Key:

I Installed

Y Separate Illustration

Copyright 1993 - 2015 Caterpillar Inc.

All Rights Reserved.