CLEVELAND BROTHERS EQUIPMENT CO INC

LOAD TEST RESULTS

Customer: Power Gen Enterprises
Engine Model:
Generator Model:
Rating: 480 VAC
Date:
S/N: X3R
S/N:
360 AMPS
Work Order:
Service Meter: ENO- 6565 hrs
Arrangement:
300 KW @ .8pF

Time of test readings	Voltage A	Voltage B	Voltage C	Amperes A	Amperes B	Amperes C	Freq. (Hz.)	Oil Press. (PSI)	Exhaust Temp.	Water Temp.	kW
18.50	480			360			60	61		190	300
18.75				360			60	50		199	300
19.0	480			360			60	49		201	300
19.25	480			360			60	49		201	300
19.50	480			360			60	50		199	300

6564.3hrs

Full load amperes based on resistive load (1.0 pF) = Amperes

Page: 1 of 1

Notes: