

## Load Bank Record

W.O # **0**

**TRI-DIESEL MAINTENANCE, LLC**  
 10826 Sageorchard Lane  
 Houston, Texas 77089  
 281-774-8818

*Cust:* **Power Generation Ent.**  
*Address:*  
*City St:* **HOUSTON, TEXAS**  
*Contact*  
*Phone:*  
*Date:* **October 29, 2015**  
*Tech:* **LINO GASPARINI**  
*Location:*

*Brand:* **DETROIT/MTU**  
*Model:* **R1637K36**  
*serial:* **5362001204**  
*Spec*  
*Engine Model:* **R1637K36**  
*Engine Serial* **5362001204**  
*KW:* **1000**      *.8pf A.* **1505**      *1pf A.* **1204**  
*Volts:* **480**      *Hours:* **6140**      *End:* **6141**

	Time	% load	Actual KW load	A	Volts B	C	Hertz	A	Amps B	C	Power Factor	Oil Press.	Water Temp	Battery Charge	Amb Air Temp.	Front Ex.Temp	Rear Ex.Temp
0	10:00	0.0		483	483	483	60					93	175	26	75		
1	10:05	65.2	652	483	483	483	60	780	780	780	1	92	178	26	75		
2	10:20	65.2	652	483	483	483	60	780	780	780	1	92	178	26	75		
3	10:21	89.9	899	483	483	483	60	1076	1076	1076	1	90	180	26	75		
4	10:36	89.9	899	483	483	483	60	1076	1076	1076	1	90	180	26	75		
5	10:37	94.7	947	483	483	483	60	1133	1133	1133	1	89	182	26	75		
6	10:52	94.7	947	483	483	483	60	1133	1133	1133	1	89	182	26	75		
7	11:07	0.0		485	483	483	60					91	177	26	75		
8																	
9																	
10																	
11																	
12																	
13																	
14																	
15																	
16																	
17																	
18																	
19																	
20																	
21																	
22																	
23																	

**Notes: UNIT DID PULL 1000 KW.**

25  
26