



Customer: Central States Diesel Generators  
 Address: 2001 S. Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847.997.8090

R#: 5378  
 Test Date 6/26/2018

Engine Make/ Model: Caterpillar C15  
 Engine Spec/ Serial: G6B10608  
 Unit Make/ Model: Caterpillar  
 Unit Spec/ Serial:

Voltage: 480  
 Amperage: 602 (482 @ 1.0 PF)  
 Kilowatts: 400  
 Power Factor 0.8

|                      | 5 Min.             | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------------------|---------|---------|---------|--------|-----------|
| Eng Hours            | 174                | 174.3   | 174.5   | 174.8   | 175    | 175       |
| Hertz/Cycles         | 60                 | 60      | 60      | 60      | 60     | 60        |
| Voltage PH1          | 480                | 480     | 480     | 480     | 480    | 480       |
| PH2                  | 480                | 480     | 480     | 480     | 480    | 480       |
| PH3                  | 480                | 480     | 480     | 480     | 480    | 480       |
| Amperage PH1         | 120                | 241     | 361     | 482     | 482    | 0         |
| PH2                  | 120                | 241     | 361     | 482     | 482    | 0         |
| PH3                  | 120                | 241     | 361     | 482     | 482    | 0         |
| Kilowatts            | 100                | 200     | 300     | 400     | 400    | 0         |
| Oil Pressure         | 84                 | 78      | 76      | 74      | 74     | 74        |
| Oil Temperature      | N/A                | N/A     | N/A     | N/A     | N/A    | N/A       |
| Coolant Temperature  | 100°F              | 130°F   | 138°F   | 149°F   | 168°F  | 170°F     |
| Man Vac./Press. L/B  | N/A                | N/A     | N/A     | N/A     | N/A    | N/A       |
| Man Vac./Press. R/B  | N/A                | N/A     | N/A     | N/A     | N/A    | N/A       |
| L/B Exhaust Temp     | N/A                | N/A     | N/A     | N/A     | N/A    | N/A       |
| R/B Exhaust Temp     | N/A                | N/A     | N/A     | N/A     | N/A    | N/A       |
| Exhaust Temperature  | N/A                | N/A     | N/A     | N/A     | N/A    | N/A       |
| DC Voltage           | 26                 | 26      | 26      | 26      | 26     | 26        |
| Natural Gas Pressure | N/A                | N/A     | N/A     | N/A     | N/A    | N/A       |
| Diesel Fuel Level    | REMOTE TANK SUPPLY |         |         |         |        |           |
| Room Temperature     | N/A                | N/A     | N/A     | N/A     | N/A    | N/A       |
| Ambient Temperature  | 88°F               | 88°F    | 88°F    | 88°F    | 88°F   | 88°F      |

Technician Signature: Jamie Merla

Customer Signature: Patrick Paden