



Dealer / Office

Doc. no./Date

07 August 2018

Page

12

ITEM	AI	QTY	MATERIAL	DESCRIPTION	L/N	LIST PRICE	NET PRICE
ENGINE UNDERSPEED SD DLY TIME							
ENGINE UNDERSPEED WN DLY TIME							
BATTERY CHARGER FOR PSPS PLATFORM							
CDVR							
IVR							
CONTROL PANEL ECM							
CONTROL PANEL FLASH FILE							
CDVR ECM							
RTD ECM							
TELEMATICS FOR PSPS							
TMC FLASH FILE							
TMC ECM							
CAT LTP LABEL							
TMC CONFIG FTP							
TELEMATICS HARDWARE CERTIFIED							
MICHIGAN TANK KIT BUNDLE							
FUEL ALARM							
FUEL SUPPLY LINES							
2							
2							
BATTERY CHARGER							
RETAIL_NA							
NO							
CONFIGURE IVR w/ PSPS							
4509606 - A5L1							
5560470 - A5L1 - ENG							
NA							
NA							
N							
NA							
NA							
N							
NA							
DECLINE / NOT APPLICABLE							
NO MICHIGAN TANK KIT BUNDLE							
No							
N							

Dealer / Office

Doc. no./Date
/ 07 August 2018

Page
3

ITEM	AI	QTY	MATERIAL	DESCRIPTION	L/N	LIST PRICE	NET PRICE
100		1	C15 PGAM	C15 T2/3 EPG PKG GEN SET			
		1	MWCODEF_I	STANDBY POWER			
		1	NACERT_I	UL & CSA CERTIFICATION			
		1	NCBG002_I	NEUTRAL CABLE GP 800A			
		1	NOCOLDB_I	NO COLD WEATHER BUNDLE.			
		1	NOENCLO_I	NO ENCLOSURE REQUIRED			
		1	NOMITKB_I	NO MICHIGAN TANK KITBUNDLE			
		1	NONIBC_I	NO SEISMIC CERTIFICATION			
		1	NONMUF_I	NO MUFFLER			
		1	NONNTD_I	NOT REQUIRED			
		1	NONSBFT_I	NO SUB BASE FUEL TANK.			
		1	NOSUSE_I	NO SUSE DECALS & FILMS			
		1	NOTREQ_I	NOT REQUIRED			
		1	NTS1_I	NEUTRAL BAR NTS1			
		1	OGNSE1N_I	LC6114F SE ALT 1N			
		1	PLGNONE_I	NO PRODUCT LINK GEN CELLULAR			
		1	PMEXC13_I	PERMANENT MAGNET EXCITATION 03			
		1	PWRCTRHI_I	POWER CENTER - RH MOUNTED			
		1	SGTF_I	RADIATOR GUARD AND DUCT FLANGE			
		1	SINGLE_I	SINGLE CIRCUIT BREAKER			
		1	STANDBY_I	STANDBY POWER			
		1	STDIVR_I	INTEGRATED VOLTAGE REGULATOR			
		1	STDNAR_I	STD NARROW SKID BASE			
		1	STDRAD_I	STANDARD RADIATOR			
		1	TCVNO_I	DECLINE / NOT APPLICABLE			
		1	60H0480_I	60HZ 480 VOLT (WYE)			
		1	ACLDE14_I	AIR CLEANER - DUAL ELEMENT 14			
		1	ADEMA4_I	ADEM A4 GOVERNOR			
		1	BAT2454_I	STANDARD WET BATTERY			
		1	BATDS03_I	BATTERY DISCONNECT SWITCH			
		1	BTC1028_I	BATTERY CHARGER 10 AMP DUAL			
		1	C15DECF_I	C15 60HZ PKG 500 CERTESE			
		1	CATDEC_I	CAT DECALS			
		1	CBAUX1_I	1ST BREAKER AUXILIARY CONTACTS			
		1	CBK0602_I	800A SINGLE MANUAL CB LSI/			
		1	CBLG002_I	CB CABLE GP ABB/T6-800/600			
		1	CERTESE_I	EPA STATIONARY EMERGENCY			
		1	CT1005A_I	1000:5 CT RATIO			
		1	EMCCAS3_I	GEN RUNNING & FAULT RELAY			

Dealer / Office

Doc. no./Date

/ 07 August 2018

Page

4

ITEM	AI	QTY	MATERIAL	DESCRIPTION	L/N	LIST PRICE	NET PRICE
				CONTROL PANEL MOUNTING LEFT			
		1	EMCCPLH_I	EMCP4.2 CONTROL PANEL			
		1	EMCP42_I	FLEXIBLE EXHAUST CONNECTION 25			
S		1	EXCFF25_S	FULL POWER			
		1	FULLPWR_I	GEN MOUNTING DUCT PLATE			
		1	GENMTG_I	130C TEMP RISE OVER 40C AMB			
		1	GENT130_I	HEATER CONTROL GROUP			
		1	HTRCG01_I	JACKET WATER HEATER 240 VAC			
		1	JWH0059_I	60 Hz, 500 kW W/Fan			
		1	KW00500_I	ENGLISH PANEL LANGUAGE			
		1	LANENGC_I	ENGLISH INSTRUCTION LANGUAGE			
		1	LANENGO_I	MANUFACTURING			
		1	MSCEC76_I	GENT130_I			
		1	GENT130_I	STD TEST - PKG GEN SET 0.8 PF			
		1	STDTEST_I	UL 2200 LISTED PACKAGE GEN SET			
		1	ULLIST_I	GENERAL EPG			
		1	MSEPGGN_I	STANDBY_I			
		1	STANDBY_I	SHRINK WRAP PROTECTION 21			
		1	SWP0021_I	PGS TEST REPORT @ 0.8 PF			
		1	TRSGEN7_I	CANADIAN STANDARDS ASSOC			
		1	TSPCSA1_I	STANDARD WARRANTY			
		1	ESCNONE_I	C15 ENGINE AR - STD			
101		1	LS1443	GENERAL AR			
102		1	3965353	Serial no.: (T3300579)			
103		1	4206876	CAPTIVE: 4206876-C15-GS667			
		Serial no.:	(FTE03685)				
104		1	4183867	GENERATOR AR-PWR			
		Serial no.:	(G6B24933)				
105		1	9Y8156	NOTE - STAMP FOR STANDBY POWER			
106		1	LS1437	UL2200 GENERATOR SET			
107		1	0V1065	END USE: EP RETAIL			
108		1	LS0259	EMCP4.2 CONTROL PANEL			
109		1	LS0262	LEFT MTD CONTROL PANEL			
110		1	LS1439	RIGHT MTD POWER CENTER			
111		1	LS1447	RADIATOR			
112		1	4235558	FILM GP (OPEN)			
113		1	LS1354	STANDARD FILM-BONDED NEUTRAL			

Dealer / Office

Doc. no./Date
07 August 2018

Page
5

ITEM	AI	QTY	MATERIAL	DESCRIPTION	L/N	LIST PRICE	NET PRICE
114	I	1	3559019	ELECTRONICS GP			
115	I	1	PP5612	779 BHP 529 GEN KW WOF 60 HZ STBY			
116	I	1	3745744	RELAY GP			
117	I	1	3745739	PANEL GP-ELEK			
118	I	1	2647114	CLEANER GP-AIR			
119	I	1	DK5575	STONE GRD & TRANSITION FLANGE			
120	S	1	3838081	FITTING GP			
121	I	1	LS0246	PERMANENT MAGNET GENERATOR			
122	I	1	LS1423	NARROW SKID BASE			
123	I	1	LS0232	BATTERY CHARGER 10 AMP DUAL/UL			
124	I	1	LS0234	STANDARD BATTERY SET			
125	I	1	3560205	SWITCH GP-DISC			
126	I	1	LS1453	JACKET WATER HEATER			
127	I	1	LS1450	TEST - PKG GEN SET			
128	I	1	0P1803	GEN SET TEST CHG AT 0.8 PF			
129	I	1	LS1451	CANADIAN STDS ASSC (CSA 22.2)			
130	I	1	CA0974	SHRINK WRAP PROTECTION			
131	I	1	4218926	KIT-LITERATURE			
132	I	1	LS1328	CURRENT TRANSFORMER			
133	I	1	LS1321	GEN MTG & DUCT PLATE			
134	I	1	LS1310	NEUTRAL BAR			
135	I	1	LS1336	SINGLE CIRCUIT BREAKERS-MANUAL			
136	I	1	LS1291	NORMAL CALBLE ENTRY PTS AND CB			
137	I	1	LS1298	NEUTRAL CABLES			
138	I	1	LS2742	AUXILIARY CONTACTS 250-800			
139	I	1	LS3103	VOLTAGE INDICATORS			
140	S	1	5P2506	LITERATURE - ENGLISH			
141	I	1	5558447	TAG-WARNING			
<p><i>With the following configuration:</i></p>							
<p>PSPS Panel Level Cstic</p>							
<p>CONFIGURATION</p>							
<p>ALTERNATOR MODEL</p>							
<p>PGS EMISSION CERTIFICATION</p>							
<p>GENSET CONTROLLER LANGUAGE</p>							
<p>DECAL LANGUAGE</p>							
<p>CONTROL PANEL MODEL</p>							
<p>VOLTAGE OPTION</p>							
<p>ENGINE RATING</p>							
<p>APPLICATION INDICATOR</p>							
<p>EXTENDED SERVICE COVERAGE</p>							
<p>A5Common Control Pnl Level 1</p>							
<p>C15 60HZ PKG 500 CERTESE</p>							
<p>6114F</p>							
<p>EPA STATIONARY EMERGENCY</p>							
<p>ENGLISH PANEL LANGUAGE</p>							
<p>ENGLISH INSTRUCTION LANGUAGE</p>							
<p>EMCP4.2 CONTROL PANEL</p>							
<p>60HZ 480 VOLT (WYE)</p>							
<p>60 Hz, 500 kW W/Fan</p>							
<p>STANDBY POWER</p>							
<p>STANDARD WARRANTY</p>							

Dealer / Office

Doc. no./Date

1 / 07 August 2018

Page

6

ITEM	AI	QTY	MATERIAL	DESCRIPTION	L/N	LIST PRICE	NET PRICE
GOVERNOR TYPE							ADEM A4 GOVERNOR
CONTROL PANEL LOCATION							CONTROL PANEL MOUNTING LEFT
ALT ATTACHMENTS							PERMANENT MAGNET EXCITATION 03
SEISMIC CERTIFICATION							NO SEISMIC CERTIFICATION
CSA CERTIFICATION							CANADIAN STANDARDS ASSOC
UL LISTING							UL 2200 LISTED PACKAGE GEN SET
MARKET SEGMENT CODES							GENERAL EPG
SUB-MARKET SEGMENT CODES							MANUFACTURING
ALTERNATOR TEMPERATURE RISE							130C TEMP RISE OVER 40C AMB
MARKET WORK CODE							STANDBY POWER
PGS TEST REPORT							PGS TEST REPORT @ 0.8 PF
SHRINK WRAP PROTECTION							SHRINK WRAP PROTECTION 21
STORAGE PRESERVATION							NO STORAGE PRESERVATION
BATTERY CHARGERS							BATTERY CHARGER 10 AMP DUAL
FREQUENCY							60 HZ
PGS NUMBER CODE							500
PHASE							3 PHASE
LINE TO LINE VOLTAGE							480
LINE TO NEUTRAL VOLTAGE							277
ENGINE MODEL							C15
KVA							625.00
RPM							1800RPM
POWER FACTOR							0.80
ALTERNATOR SERIES							6100
ALTERNATOR							LC6114F SE ALT 1N
KW							500.0
EXHAUST FLEX FITTING-ADAPTERS							FLEXIBLE EXHAUST CONNECTION 25
AIR CLEANER (ENGINE)							AIR CLEANER - DUAL ELEMENT 14
RADIATOR							STANDARD RADIATOR
TARIFF (COMMODITY) CODE							Output> 375kVA <= 750kVA
NO OF WIRES-ALT CONN							4 WIRE
ALTERNATOR ELECT. CONNECTION							S-STAR
PRODUCT_DIVISION							STANDARD (10)
ALTERNATOR WINDING							12 WIRE WINDING
ALTERNATOR IP RATING							IP23 PROTECTION
BRAND							CATERPILLAR
SPECIAL ALTERNATOR							N
SPECIAL ENCLOSURE							N
SPECIAL VOLTAGE							N
SPECIAL RADIATOR (COOLING SYS)							N

Dealer / Office

Doc. no./Date

/ 07 August 2018

Page

7

ITEM	AI	QTY	MATERIAL	DESCRIPTION	L/N	LIST PRICE	NET PRICE
			SPECIAL CONTROL PANEL		N		
			SPECIAL BATTERY		N		
			SPECIAL CIRCUIT BREAKER		N		
			SPECIAL GOVERNOR		N		
			SPECIAL BASE (MOUNTING)		N		
			SPECIAL EXHAUST SYSTEM		N		
			SPECIAL PAINT COLOUR		N		
			SPECIAL ENGINE		N		
			SPECIAL AVR		N		
			SPECIAL REMOTE FUEL SYSTEM		N		
			SPECIAL RATING		N		
			SPECIAL SECONDARY FUEL FILTER		N		
			USER				
			VOLTAGE REGULATOR				ORDER PROCESSING
			JACKET WATER HEATER				INTEGRATED VOLTAGE REGULATOR
			BATTERY OPTIONS				JACKET WATER HEATER 240 VAC
			ENCLOSURE				STANDARD WET BATTERY
			CURRENT TRANSFORMER				NO ENCLOSURE REQUIRED
			AMPS (FULL LOAD CURRENT)				1000:5 CT RATIO
			CURRENT TRANSFORMER RATIO				752
			BASE TYPE (MOUNTING OPTION)				1000/5A
			REGULATOR EXCITATION TYPE				STD NARROW SKID BASE
			GENSET SPECIFICATION				SELF EXCITED
			ENGINE PERFORMANCE SPEC				PP-5612
			SHIP LOOSE NAMEPLATE				762 BHP @1800 RPM
			GEN RUNNING & FAULT RELAY				N
			VOLTAGE ADJUST POTENTIOMETER				GEN RUNNING & FAULT RELAY
			HEATERS CONTROL GROUP				N
			RADIATOR GUARD AND DUCT FLANGE				HEATER CONTROL GROUP
			ENCLOSURE DOOR OPTION				RADIATOR GUARD AND DUCT FLANGE
			CURRENT DROOP TRANSFORMERS				N
			SUB BASE FUEL TANK				N
			BATTERY DISCONNECT SWITCH				NO SUB BASE FUEL TANK.
			TESTING - GENERATOR SET				BATTERY DISCONNECT SWITCH
			POWER TERMINAL STRIP				STD TEST - PKG GEN SET 0.8 PF
			1ST CIRCUIT BREAKER				N
			2ND CIRCUIT BREAKER				800A SINGLE MANUAL CB LS/I
			CIRCUIT BREAKER AUX CONTACTS				N
			BREAKER SEPARATION PLATE				1ST BREAKER AUXILIARY CONTACTS
			POWER CENTER LOCATION				N
							POWER CENTER - RH MOUNTED

Dealer / Office

Doc. no./Date
/ 07 August 2018

Page
9

ITEM	AI	QTY	MATERIAL	DESCRIPTION	L/N	LIST PRICE	NET PRICE
			AMPS (FULL LOAD CURRENT)		752		
			SPECIAL CONTAINER		N		
			CB NEUTRAL CABLES			NEUTRAL CABLE GP 800A	
			2ND NEUTRAL CABLES		N		
			LOAD TRANSFER PANEL			NO LOAD TRANSFER PANEL	
			TOP CABLE ENTRY LTP		NR		
			SOLID NEUTRAL LINK (TLINK)		NR		
			VOLTAGE SENSING TAP (VST)		NR		
			AUXILIARY CONTACTS (TAUX)		NR		
			TERMINAL SHROUD LTP (TIP1)		NR		
			LOAD TRANSFER PANEL OPTION		NR		
			EXTENDED LOAD TERMINAL (TELT)		NR		
			LIGHTING PROTECTION KIT (TLPR)		NR		
			IP54 PROTECTION KIT (TIP5)		NR		
			VLT FR CONTACTS MAIN /GEN TI02		NR		
			POWER METERING (TMET)		NR		
			COMMUNICATION MODULE (TCOM)		NR		
			CONTROL PANEL MODEL PROD		NR	EMCP42_I	
			3RD CIRCUIT BREAKER			NO THIRD BREAKER	
			CIRCUIT BREAKER 3 AUX CONTACT		N		
			CB3 NEUTRAL BARS		N		
			CERTIFICATION			UL & CSA CERTIFICATION	
			3RD POWER CENTRE CABLES			NOT REQUIRED	
			3RD NEUTRAL CABLES		N		
			BASE TYPE (MOUNTING OPTION)		STDNAR_I		
			BATTERY OPTIONS		BAT2454_I		
			GEN MOUNTING & DUCT PLATE			GEN MOUNTING DUCT PLATE	
			GOVERNOR TYPE		ADEMA4_I		
			ENGINE MODEL		C15		
			RADIATOR		STDNAR_I		
			PGS TEST REPORT		TRSGEN7_I		
			VOLTAGE OPTION		60H0480_I		
			ENCLOSURE			NO ENCLOSURE REQUIRED	
			SPECIAL PAINT - PANEL			NOT RELEVANT	
			SPECIAL PAINT - BASE			NOT RELEVANT	
			SPECIAL MUFFLER		N		
			SPECIAL PAINT - ENCLOSURE			NOT RELEVANT	
			SPECIAL PAINT - ENGINE			NOT RELEVANT	
			SPECIAL PAINT - CIRCUIT BREAKER			NOT RELEVANT	
			SPECIAL PAINT - ALTERNATOR			NOT RELEVANT	

Dealer / Office

Doc. no./Date
07 August 2018

Page
10

ITEM	AI	QTY	MATERIAL	DESCRIPTION	L/N	LIST PRICE	NET PRICE
MUFFLERS					NONMUF_I		
SPECIAL HEAT EXCHANGER					N		
PANEL TYPE					NOT APPLICABLE		
NFPA110 BUNDLE					NO NFPA 110 BUNDLE		
FUEL TANK RISER					N		
ENGINE PERFORMANCE SPEC					N		
ENGINE PERFORMANCE SPEC					0K-6281		
SPECIAL GENSET SPECIFICATION					N		
SPECIAL PGS CODE/ GENSET MODEL					N		
ALTITUDE (M ABOVE SEA LEVEL)					1,000.0		
TEMPERATURE (DEGREE CELSIUS)					40		
GENSET SPECIFICATION					PP-5612		
PGS CODE / GENSET MODEL					500		
ALTERNATOR TEMPERATURE RISE					GENT130_I		
SPECIAL ALTERNATOR TEMPERATURE					NOT RELEVANT		
GENSET ENCLOSURE COLOUR SCHEME					N		
SOLUTION SET BUILD INDICATOR					N		
WIRING FOR CANOPY SPACE HEATER					NOT REQUIRED		
ALTERNATOR INSULATION CLASS					CLASS H		
SPECIAL ALT EXCITATION VOLTAGE					N		
SPECIAL MASS					N		
1 METER DECIBEL AWEIGHT					N		
SPECIAL ALT EXCITATION CURRENT					N		
CUSTOMS UNION CERTIFICATION					NOT REQUIRED		
DAMPER					N		
ELECTRICAL SVR BUILD					N		
ALTERNATOR IP RATING					23		
SPECIAL ALTERNATOR IP RATING					NO ALTERNATOR IP RATING		
MECHANICAL SVR BUILD					N		
APPLICATION INDICATOR					STANDBY_I		
SPECIAL APPLICATION INDICATOR					N		
RTD					N		
COLD WEATHER BUNDLE					NO COLD WEATHER BUNDLE.		
TELEMATICS HARDWARE					NO PRODUCT LINK GEN CELLULAR		
CONTROL PANEL SOFTWARE TYPE.					STANDARD SOFTWARE		
DIGITAL OUTPUT #15					NOT APPLICABLE		
DIGITAL INPUT #01					COOLANT LEVEL - LOW SD		
START AID ACTIVATION TIME					0 seconds		
DIGITAL INPUT #02					DISABLED		
ENGINE MODEL FOR PSPS					C15LNA		

