



Customer: Central States Diesel Generators STK#2423

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-995-7655

R#: 6817

Test Date 3-6-2019

Engine Make/ Model: Detroit Diesel Series 60

Engine Spec/ Serial: 06R0969038

Voltage: 277/480

Amperage: 505

Unit Make/ Model: Detroit Diesel 400DSED

Kilowatts: 420

Unit Spec/ Serial: Spec. GM41981-GA1S

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	61.2	61.5	61.7	62	62.2	62.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	481	480	480	480
PH2	481	481	481	480	481	481
PH3	480	481	480	481	481	480
Amperage PH1	0	505	505	505	505	0
PH2	0	504	505	505	505	0
PH3	0	505	504	505	504	0
Kilowatts	0	420	420	420	420	0
Oil Pressure	55	50	49	49	49	50
Oil Temperature						°F
Coolant Temperature	182°F	185°F	185°F	185°F	185°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.4	27.4	27.4	27.4	27.4	27.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	7°F	7°F	7°F	7°F	7°F	8°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_