



Load Bank Test Form

Customer Name PGE Date 5/28/2019
 Test Address 11440 Smith Rd Technician Justin Pitts
Humble Texas Witness _____
 Gen. Rating 800 KW 750kw Job # 3557 HTS
 Gen. Mfg. CATERPILLAR Gen. S/N ~~7A304~~ 7AJ01803
 Engine S/N 2WJ02530

TIME	Load %	kW	Amps			Volts			Hz	Oil Press.	Water Temp.	Ambient Temp.
			A	B	C	A-B	A-C	B-C				
2:00	0	0	0	0	0	480	480	480	60	81	160	87°F
2:10	25	200	262	262	262	480	480	480	60	73	182	87°F
2:20	25	200	262	262	262	480	480	480	60	73	182	87°F
2:30	50	375	450	451	452	480	480	480	60	69	190	87°F
2:40	50	375	450	451	452	480	480	480	60	69	190	87°F
2:50	75	532	641	642	641	480	480	480	60	64	196	87
3:00	75	532	641	642	641	480	480	480	60	64	196	87
3:10	100	730	892	893	892	480	480	480	60	64	198	87
3:15	100	730	893	893	892	480	480	480	60	64	199	87
3:30	100	730	892	893	892	480	480	480	60	63	200	87
3:35	100	730	893	894	892	480	480	480	60	64	200	87
3:40	100	730	891	893	892	480	480	480	60	64	200	87
3:45	100	730	891	894	891	480	480	480	60	64	200	87
3:50	100	730	891	893	891	480	480	480	60	64	200	87
3:55	100	730	891	894	891	480	480	480	60	64	200	87
4:00	0	0	0	0	0	480	480	480	60	64	176	87

Comments : _____

