

CATERPILLAR C32 GENERATOR SET

Reference Number	Eng	Chg	Quantity	ASM	LESS	Set Type	Description
C32DE34	F		1	I			C32, 60HZ, 1800RPM PGS 34
OGPM363	F		1	I			GEN-1424-600V-PM-RTD-2B
RPA0344	F		1	I			1402/2B IE GENERATOR REMOVAL44
CT150A5	F		1	I			CURRENT TRANSF., 1500:5 RATIO
NOEUCRT	F		1	I			NO EURO DIRECTIVE REQUIRED
BTC1032	F		1	S			BATTERY CHARGER 10 AMP
JWHWP08	F		1	I			*OLD*JWH WITH PUMP 208/240V
BAT2416	F		1	I			STARTING SYSTEM
BATRM03	F		1	I			STANDARD BATTERY REMOVAL
BTC2416	F		1	I			CHARGING ALTERNATOR-45AMP
TSPCSA4	F		1	I			CSA TEST AND CERTIFICATION
NGRDCNC	F		1	I			NEUTRAL GND CONNECTION C
PES1D1L	F		1	I			CBK UL 3P 1200A 100% LSI EO
BUS146R	F		1	I			5000A LV BB REMOVAL (NEMA)1400
BUSCB14	F		1	I			BUS BAR CONNECTIONS-1400 FRAME
BOTCBLL	F		1	I			BOTTOM CBL ENTRY NO SHROUD STD
SUPCBL1	F		1	I			SUPPORT GROUP
PCLH009	F		1	I			CONNECTION GROUP PCLH009_I
AUXPNLL	F		1	I			AUXILIARY PLATE MOUNTING - LH

CUSTCNR	F	1	I	CUSTOMER CONNECTION MTG RH STD
EMCP42	F	1	I	EMCP 4.2 CONTROL PANEL (STD)
NOENCPB	F	1	I	NO ENCLOSURE REAR (STANDARD)
NOENCPR	F	1	I	NO ENCLOSURE RIGHT (STANDARD)
UIPBBHS	F	1	I	CONTROL PANEL MOUNT REAR (STD)
STANDBY	F	1	I	STANDBY POWER APPLICATION
CERTESE	F	1	I	PACKAGE GEN SET
60H0600	F	1	I	60HZ 600 VOLTS
MSEPGGN	F	1	I	GENERAL EPG (NON-ENCLOSED)
TRSGEN1	F	1	I	GENERATOR TEST REPORT
TRSGEN7	F	1	I	PGS TEST REPORT @ 0.8 PF
MWCODEF	F	1	I	STANDBY POWER
MSCEC70	F	1	I	ENERGY UTILITIES
KW01000	F	1	I	1000 EKW W/FAN
LANENGO	F	1	I	ENGLISH LANGUAGE OPTION
NONULL	F	1	I	NON UL 2200 LISTED PKG GEN SET
GENT105	F	1	I	105 DEG GENERATOR TEMP RISE