

3508 GEN SET ENGINE

Engine Serial Number - 1ZF (Build Date - 01/1992, Test Date - 02/1992, Ship Date - 02/1992)

▼ ENGINE - ENTIRE GROUP (1ZF)

<u>Qty.</u>	<u>NPR</u>	<u>Note</u>	<u>Part No.</u>	<u>Change Level</u>	<u>Req. Qty</u>	<u>Part Name</u>
		I	PA2592	11	001	PART NUMBERS 3508 DITA PACKAGE GEN SET-S
	NPR	IY	7C-8108	09	001	ENGINE AR
		I	3L-0348		001	PACKAGE GS TEST - EMCP
		I	5N-7562	00	001	CHART
		I	5N-7574		001	NOTE-CTL&PWR.PANL CHART 7C1000
		I	5P-2506	00	001	LITERATURE GP
	NPR	IY	7C-0526	00	001	STARTING MOTOR GP-ELECTRIC
	NPR	I	7C-1621	00	001	GENERATOR AR
	NPR	IY	7C-1665	03	001	DRIVE GP-FAN
	NPR	IY	7C-2459	01	001	GUARD GP-BELT
	NPR	I	7C-2561	01	001	CONNECTION GP-GENERATOR LEADS
	NPR	IY	7C-5702	07	001	HARNESS GP-WIRING
	NPR	IY	7C-6513	06	001	CONTROL GP-EMCP ELECTRONIC
	NPR	I	7C-6795	02	001	CONNECTION GP-ELECTRICAL
	NPR	IY	7C-7827	02	001	MOUNTING GP-RADIATOR
	NPR	IY	7C-7831	02	001	LINES GP-WATER
	NPR	IY	7C-8124	03	001	HOUSING & REGULATOR GP
	NPR	I	7W-0919	01	001	MOUNTING GP-CONTROL PANEL
	NPR	IY	7W-3749	02	001	RAIL GP-ENGINE SUPPORT
	NPR	IY	7W-5639	01	001	FAN GP-BLOWER
	NPR	IY	7W-6669	01	001	GUARD GP-DAMPER
	NPR	IY	7W-8138	00	001	PULLEY GP-FAN DRIVE
	NPR	I	7W-8708	00	001	INSTALLATION AR-GENERATOR
	NPR	IY	8N-9639	04	001	GUARD GP-DAMPER
	NPR	IY	9Y-0128	06	001	FASTENER GP-WIRING HARNESS
	NPR	IY	9Y-4859	00	001	FASTENER GP-RADIATOR
	NPR	IY	7E-7528	01	001	RADIATOR GP
	NPR	IY	4P-0556	01	001	MOUNTING GP-AIR CLEANER
	NPR	IY	4P-0558	00	001	AIR CLEANER GP
	NPR	I	4P-2530	00	001	INDICATOR GP
	NPR	IY	4P-2588	00	001	MOUNTING GP-CONTACTOR
		I	3L-0414		001	SINGLE BEARING GEN ALIGN-3500
	NPR	IY	9Y-7695	00	001	SWITCH GP-COOLANT LEVEL

	NPR	IY	9Y-5563	00	001	FUMES DISPOSAL GP
	NPR	IY	5N-2438	05	001	LINES GP-FLEXIBLE FUEL
	NPR	IY	9Y-6496	02	001	MODULE GP-INTERFACE
	NPR	IY	3N-7056	00	001	SUPPORT GP-BATTERY
		I	PA4361	01	001	JACKET WATER HEATER - DUAL
	NPR	I	7E-6247	00	001	HEATER GP-JACKET WATER
	NPR	IY	6I-1039	00	001	MOUNTING GP-JACKET WTR HEATER
	NPR	IY	6I-1040	01	001	MOUNTING GP-JACKET WTR HEATER
		I	0P-9812		001	EB3LJR4DXXXXP1VE4 EMCP PANEL
		I	PA4076	00	001	CIRCUIT BREAKER-1600 AMP W/S
	NPR	I	4P-3840	00	001	CIRCUIT BREAKER AS
	NPR	I	7C-0301	02	001	HARNESS AS-PANEL
	NPR	I	7C-2206	01	001	MOUNTING GP-CIRCUIT BREAKER
	NPR	I	9Y-8443	00	001	PANEL AS-BOX
		I	PP0644	00	001	1456 BHP 1017 GEN KW 60 HZ SB
		I	0T-8144	00	001	1086 KW @ 1800 RPM (1456 BHP)
		I	0P-8709		001	STANDBY ALLOW PGM - PGM 344
		I	0P-9883		001	0P9883 STANDBY PLUS PGM 344
		I	0P-9872		001	PRE 01JAN92 PRC STBYPGM515-1