

3508 GEN SET ENGINE

Engine Serial Prefix - 1ZF (Build Date - 08/1989, Test Date - 08/1989, Ship Date - 08/1989)

▼ ENGINE - ENTIRE GROUP (1ZF)

<u>Qty.</u>	<u>NPR</u>	<u>Note</u>	<u>Part No.</u>	<u>Change Level</u>	<u>Req. Qty</u>	<u>Part Name</u>
		I	PA2592	03	001	PART NUMBERS 3508 DITA PACKAGE GEN SET-S
	NPR	IY	7C-8108	08	001	ENGINE AR
		I	3L-0348		001	PACKAGE GS TEST - EMCP
		I	5N-7562	00	001	CHART
		I	5N-7574		001	NOTE-CTL&PWR.PANL CHART 7C1000
		I	5P-2506	00	001	LITERATURE GP
	NPR	IY	7C-0526	00	001	STARTING MOTOR GP-ELECTRIC
	NPR	I	7C-1435	02	001	CONNECTION GP-TERMINAL STRIP
	NPR	I	7C-1621	00	001	GENERATOR AR
	NPR	IY	7C-1665	03	001	DRIVE GP-FAN
	NPR	IY	7C-2459	01	001	GUARD GP-BELT
	NPR	I	7C-2561	01	001	CONNECTION GP-GENERATOR LEADS
	NPR	IY	7C-5702	03	001	HARNESS GP-WIRING
	NPR	IY	7C-6513	02	001	CONTROL GP-EMCP ELECTRONIC
	NPR	I	7C-6795	00	001	CONNECTION GP-ELECTRICAL
	NPR	IY	7C-7825	02	001	RADIATOR GP
	NPR	IY	7C-7827	02	001	MOUNTING GP-RADIATOR
	NPR	IY	7C-7831	02	001	LINES GP-WATER
	NPR	IY	7C-8124	01	001	HOUSING & REGULATOR GP
	NPR	IY	7E-5546	00	001	MOUNTING GP-CONTACTOR
	NPR	I	7W-0919	01	001	MOUNTING GP-CONTROL PANEL
	NPR	IY	7W-3749	02	001	RAIL GP-ENGINE SUPPORT
	NPR	IY	7W-5639	00	001	FAN GP-BLOWER
	NPR	IY	7W-6669	01	001	GUARD GP-DAMPER
	NPR	IY	7W-8138	00	001	PULLEY GP-FAN DRIVE
	NPR	I	7W-8708	00	001	INSTALLATION AR-GENERATOR
	NPR	IY	8N-9639	03	001	GUARD GP-DAMPER
	NPR	IY	9Y-0128	02	001	FASTENER GP-WIRING HARNESS

	NPR	IY	9Y-3878	01	001	AIR CLEANER GP
	NPR	IY	9Y-4859	00	001	FASTENER GP-RADIATOR
	NPR	IY	7C-5296	00	001	PANEL GP-INSTRUMENT
	NPR	IY	9Y-6095	02	001	PUMP GP-FUEL PRIMING
		I	PA2354	03	001	CHARGING ALTERNATOR 24V 35AMP
	NPR	IY	7C-4803	02	001	ALTERNATOR GP-CHARGING
	NPR	IY	7C-5025	01	001	MOUNTING GP-CIRCUIT BREAKER
	NPR	I	7E-4836	01	001	MOUNTING GP-ALTERNATOR
	NPR	IY	7W-5780	02	001	GUARD GP-BELT
	NPR	IY	7W-9640	00	001	CIRCUIT BREAKER GP
	NPR	IY	7C-1704	02	001	HEATER GP-JACKET WATER
		I	0P-9661		001	LUBE OIL - DO NOT DRAIN
		I	0P-9812		001	EB3LJR4DXXXXP1VE4 EMCP PANEL
	NPR	IY	9Y-7695	00	001	SWITCH GP-COOLANT LEVEL
		I	0P-9715		001	EXTRA LITERATURE - ENGLISH
		I	PP0644	00	001	1456 BHP 1017 GEN KW 60 HZ SB
		I	0T-8144	00	001	1086 KW @ 1800 RPM (1456 BHP)
		I	0P-8709		001	STANDBY ALLOW PGM - PGM 344
		I	0P-9362		001	CCS ENGINE CERTIFICATION

Key:

I Installed

Y Separate Illustration