

LOAD BANK TEST REPORT

FACILITY Intermaintain Motor

DATE 8-29-16

NAMEPLATE DATA

KW 455

KVA 568

PF _____

VOLTS 480

AMPS 683

HZ 60

| TIME | VOLTS | | | AMPS | | | HZ | HOURS | OIL PRESS | WATER TEMP | KW |
|-------|-------|-----|-----|------------------|-------|-------|-------|-------|-----------|------------|-----|
| | A-B | B-C | C-A | A | B | C | | | | | |
| L | | | | | | | | | | | |
| G | | | | | | | | | | | |
| 12:30 | 479 | 479 | 479 | 59.9 | 59.8 | 59.8 | 59.99 | 3437 | 79 | 169 | 80 |
| 12:45 | 479 | 479 | 479 | 183.3 | 183.0 | 183.0 | 59.98 | 3437 | 75 | 187 | 150 |
| 1:00 | 478 | 478 | 478 | 307.0 | 306.6 | 306.3 | 59.99 | 3438 | 73 | 192 | 250 |
| 1:30 | 476 | 476 | 476 | 551 | 550.5 | 550 | 60.01 | 3438 | 71 | 197 | 450 |
| 2:00 | 476 | 476 | 476 | 551 | 550 | 550 | 60.01 | 3439 | 70 | 200 | 450 |
| 2:30 | 476 | 476 | 476 | 551 | 550 | 550 | 60.01 | 3439 | 70 | 203 | 450 |
| 3:00 | 476 | 476 | 476 | 550 | 549 | 549 | 60.01 | 3440 | 70 | 205 | 450 |
| 3:30 | 476 | 476 | 476 | 550 | 549 | 549 | 60.01 | 3440 | 70 | 205 | 450 |
| 4:00 | 476 | 476 | 476 | 550 | 550 | 550 | 60.00 | 3441 | 70 | 209 | 450 |
| 4:30 | 476 | 476 | 476 | 550 | 550 | 550 | 60.00 | 3441 | 70 | 209 | 450 |
| | | | | | | | | | | | |
| | | | | | | | | | | | |