

Charles EQUIPMENT ENERGY SYSTEMS

530 Santa Rosa Drive. Des Plaines, IL 60018 Phone (630) 834-6000 Fax (630) 543-4174

"TAKE ADVANTAGE OF OUR FULL LINE OF RENTAL GENERATORS AND POWER DISTRIBUTION"

Generator Make & Model: Caterpillar 3508

Serial No.: 23Z05318

Rating: kW 750 Volts 277/480 Amps 902 Hertz 60 P.F. 1.0

Run Time	10 min	10 min	10 min	10 min	10 min	10 min	10 min	10 min
% Rated Load	0	100	100	100	100	100	100	0
Hertz/Cycles	60	60	60	60	60	60	60	60
Voltage PH1	480	481	480	482	481	480	481	481
PH2	482	481	481	481	480	482	480	480
PH3	482	482	480	481	482	482	481	481
Amperage PH1	0	902	901	902	900	902	901	0
PH2	0	901	902	902	903	900	901	0
PH3	0	902	902	903	902	903	902	0
Kilowatts	0	750	750	750	750	750	750	0
Oil Pressure	62	60	55	55	55	55	54	59
Coolant Temperature	Warm-up	175	175	175	175	175	175	Cooldown
DC Voltage	28	27	27	27	27	27	27	27
DC Amperage	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Natural Gas Press	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Diesel Fuel Level	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Ambient Temp	40	41	41	41	41	41	41	41
Hour Meter	1511	1511	1511	1511	1511	1511	1511	1511

FIELD NOTES

TEST DATE: 2-15-17

CEES

TECHNICIAN(S):

Randy P.

PAGE 1 of 1

LOAD BANK TESTING RESULTS