LOAD TEST REPORT

GenSolutions LLC

14519 E Fwy
Texas, 77015

Houston
936-443-4378

Account Name:
Power Generation Enterprises

Equipment Location: (Physical Address)
11519 E Fwy

Work Order Number:

Engine	Generator
Cummins	Newage
QST-30-G5 NR2	AO4I2Y8386
37226397	

PASS / FAIL
PASS

Engine Fluids:

Engine Fluids:	
Oil Level	OK
Coolant Level	OK
Beg. Fuel Level	350
End Fuel Level	275

Service Technician	Test Date
Joseph Harvey	Thursday, September 7, 2017

Customer Witness

Test Equipment

Make:	AVTRON
Model:	1250 KW
Serial Number:	138

Line	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (KW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Pressure (PSI)	Water Temp (F)	Ambient Temp (F)
1	10:45	2062.8	480	60	0	0	0	0	77	75	75
2	10:50	2063	480	60	250	292	291	191	67	156	75
3	11:05	2063.2	480	60	500	625	628	535	58.5	174	76
4	11:20	2063.4	480	60	750	941	928	838	55.4	174	76
5	11:35	2063.6	480	60	1000	1185	1200	1106	52.2	175	76
6	11:40	2063.7	480	60	500	543	634	630	55.1	171	76
7	11:45	2063.8	480	60	0	0	0	0	56.5	169	76
8											
9											
10											
11											
12											
13											