



Customer: Central States Diesel Generators STK#2453
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 7008
 Test Date 4-16-2019

Engine Make/ Model: Caterpillar 3412
 Engine Spec/ Serial: 2WJ02110
 Unit Make/ Model: Caterpillar 3412
 Unit Spec/ Serial: 2WJ02110

Voltage: 277/480
 Amperage: 1091
 Kilowatts: 725
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	7706	7706	7706	7706	7707	7707
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	479	480	480	480
PH2	481	481	481	481	480	481
PH3	479	480	479	479	480	479
Amperage PH1	0	872	873	873	872	0
PH2	0	871	874	874	873	0
PH3	0	873	874	873	874	0
Kilowatts	0	725	725	725	725	0
Oil Pressure	90	70	67	66	66	71
Oil Temperature						
Coolant Temperature	180°F	183°F	184°F	184°F	184°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	50°F	50°F	50°F	51°F	51°F	51°F

Technician Signature: Randy Pool

Customer Signature: _____