


**Cleveland Brothers Equipment Co., Engine Test Report**

of

Customer: \_\_\_\_\_  
 Engine/Generator S/N: 2ED00703 \_\_\_\_\_ RPM/Hz \_\_\_\_\_ 1800  
 Test Location: Naval Base \_\_\_\_\_  
 Test Performed By: A de Bock \_\_\_\_\_  
 Test Witnessed By:  \_\_\_\_\_

Date: 10/7/16  
 Gen KW: 2000

Time	Hour Meter	Fuel Pressure	Water Temp	Oil Pressure	Volts A/C	Hertz	Amps Phase 1	Amps Phase 2	Amps Phase 3	Kilowatts (MW)	Ambient Temp (F)
7:45	1241	50	170	60	480	60.5	2623	2285	2328	1999	55
8:00	1242	55	170	60	482	60.5	2622	2272	2321	1999	55
8:15	1242	55	170	60	482	60.5	2622	2272	2321	1999	55
8:30	1242	55	170	60	482	60.5	2622	2272	2321	1999	55
8:45	1242	55	170	60	482	60.5	2622	2272	2321	1999	55
9:00											
9:15											
9:30											
9:45											
10:00											
10:15											
10:30											
10:45											
11:00											
11:15											
11:30											
11:45											



Certified By: \_\_\_\_\_  
 Authorized Cleveland Brothers Co Representative

Date: \_\_\_\_\_

6