



Customer: Central States Diesel Generators STK#2289  
 Address: 2001 S Prairie Avenue  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 5464  
 Test Date 6/13/2018

Engine Make/ Model: International GCD325  
 Engine Spec/ Serial: WS4486N1459327  
 Unit Make/ Model: Olympian D200P4  
 Unit Spec/ Serial: OLY00000ENNS01189

Voltage: 277/480  
 Amperage: 241  
 Kilowatts: 200  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	219,3	219,5	219,8	220	220,3	220,4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	482	482	482	482	482	482
PH2	482	482	482	482	482	482
PH3	482	482	482	482	482	482
Amperage PH1	0	240	240	239	240	0
PH2	0	239	239	239	239	0
PH3	0	240	239	240	239	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	55	52	52	52	52	54
Oil Temperature						
Coolant Temperature	185°F	190°F	190°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27,5	27,5	27,5	27,5	27,5	27,5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	77°F	77°F	77°F	77°F	77°F	77°F

Cable Length: \_\_\_\_\_

Cable/ Leg: \_\_\_\_\_

Connection Point: \_\_\_\_\_

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_