



225 Nichols Ave, Dickinson TX 77539  
713-823-0890

### LOAD TEST REPORT

Account Name: PK  
 Equipment Location: (Physical Address) \_\_\_\_\_  
 Work Order Number: \_\_\_\_\_

Engine: 351L Generator: cat  
BAFF / H20246A

PASS / FAIL

Engine Fluids:  
 Oil Level: Full  
 Coolant Level: Full  
 Battery Fuel Level: 2590  
 Engine Fuel Level: \_\_\_\_\_

Service Technician: Devon Epps Test Date: 2-24-25  
 Customer Witness: \_\_\_\_\_

Test Equipment  
 Make: \_\_\_\_\_  
 Model: \_\_\_\_\_  
 Gen Set SN: \_\_\_\_\_

Line	Time	Hour Meter	Volt Meter	Frequency (Hz)	Power (KW)	Leg A Amps	Leg B Amps	Leg C Amps	Oil Pressure (PSI)	Water Temp (F)	Ambient Temp (F)
	3:00	4445	480	60	259	302	303	304	94	123	
	3:14	4445	480	60	503	589	585	592	82	159	
	3:22	4445	480	60	749	878	873	882	70	179	
	3:30	4445	480	60	1002	1186	1176	1191	69	179	
	3:40	4445	480	60	1244	1462	1461	1474	66	181	
	3:50	4445	480	60	1506	1763	1764	1777	64	183	
	4:00	4446	480	60	1873	2193	2198	2211	62	188	

NO issues with unit.